

A Verification of SAR Measurement for APD Evaluation at frequency 6 GHz to 10 GHz

Yuto Shimizu ⁽¹⁾, Hiroshi Kawakami ⁽¹⁾, and Tomoaki Nagaoka ⁽¹⁾

(1) National Institute of Information and Communications Technology,
4-2-1, Nukui-kitamachi, Koganei, Tokyo, Japan; e-mail: y_shimizu@nict.go.jp

In recent years, wireless communication devices have been widespread. Wireless communication devices used in close proximity to a human body need to be assessed for human exposure. For instance, in a frequency band used by the commercially smartphones (700 MHz to 6GHz), SAR (specific absorption rate) is used as the safety criteria [1]. The measurement procedure for the compliance test of wireless communication devices using SAR have been standardized by IEC (International Electrotechnical Committee) and IEEE (Institute of Electrical and Electronics Engineers) [2]. Recently, the compliance test method based on an APD (absorbed power density) at frequencies from 6 GHz to 10 GHz has been published as PAS (publicly available specification) by IEC [3]. This method obtains the APD using SAR that is measured based on the compliance test standard [2]. Specifically, 8 g averaged SAR is converted to 4 cm² averaged APD. Therefore, when APD is evaluated for the compliance test at the frequency from 6 GHz to 10 GHz, SAR measurement system is used. In addition, current compliance test standard using SAR [2] can be applied at the frequency including 6 GHz to 10 GHz. Therefore, to verify whether our SAR measurement system can obtain SAR based on the compliance test standard [2], 8 g averaged SAR was measured using the reference dipole antenna at the frequency range from 6 GHz to 10 GHz. Additionally, the uncertainty of the SAR measurement system was also evaluated.

Figure 1 shows the measurement setup. In this study, we used DASY 6 which is commercially SAR measurement system provide by Schmid & Partner Engineering AG. This measurement uses a flat phantom filled with the tissue equivalent liquid which dielectric property specified in the standard [2] and the dipole antenna whose length is specified for each frequency. The dipole antenna is spaced 5 mm apart at the bottom center of flat phantom. 8 g averaged SAR is measured with the input power of 22 dBm applied to the dipole antenna. In this study, 8 g averaged SAR is evaluated at frequency 6.5 GHz, 7 GHz, 8 GHz, and 9 GHz. The measured SAR was compared with the numerical reference calculated by the electromagnetic simulation. The uncertainty of the SAR measurement system was also evaluated according to the standard [2]. The difference between the measured and numerical 8 g averaged SAR was within 10 % in each frequency. It indicates the viridity of the SAR measurement at frequency 6 GHz to 10 GHz. The uncertainty evaluation confirmed that the expanded uncertainty over 6 GHz was larger than that below 6 GHz.




Figure 1. Setup for the system validation of the SAR measurement system.

Acknowledgement

This work was supported by the Ministry of Internal Affairs and Communications of Japan (JPMI10001).

References

- [1] ICNIRP, *Health Phys.*, vol. 74, no. 10, pp. 494-522, 1998.
- [2] IEC/IEEE 62209-1528, 2020.
- [3] IEC PAS 63446, 2022.

This paper's copyright is held by the author(s). It is published in these proceedings and included in any archive such as IEEE Xplore under the license granted by the "Agreement Granting URSI and IEICE Rights Related to Publication of Scholarly Work."